





22.34













- Open Type Device Pollution degree 2 Installation Environment
- Maximum Surrounding Air Temperature 50°C
- Minimum distance among modular contactors 9 mm
- Field Wiring Terminals:
- Use 60/75°C copper conductor only and wire ranges No. 10-12-18-24 AWG, Solid only
- Terminal tightening torque 7.0 lb.in. (0.8 Nm)
- Suitable for use on a circuit capable of delivering not more than 5000 ARMS Symmetrical, 240 V AC, when protected by Listed Cartridge Fuses, rated K5 Class (No Current Limiting, Non-Time Delay, max 600 V AC, 30 A, 50 kA A.I.C.) or RK5 Class (Current Limiting, Time Delay, max 600 Vac, 15 A, 50 kA A.I.C.) or equivalent.
- For use in a circuit protected by Type1 or Type2 Surge Protective Devices with "Max Voltage Protection" rating of 3.7 kVpk and "Minimum Nominal Discharge Current" of 5 kA (at 6 kV).




# 22.34 + (022.33 / 022.35)



35







#### 22.34 MODULAR CONTACTOR 25 A

Contact gap  $\geq$  3 mm for NO contacts only. NC contacts  $\geq$  1.5 mm. Compliant with EN 61095: 2009. AC/DC silent coil (with varistor protection).

- **1** CONNECTION DIAGRAM
- **2** OUTLINE DRAWINGS
- **3** FRONT VIEW

A = Selector (22.34.0.xxx.xx40)

The three-position manual selector has the following functions:

#### ON position

The contacts are latched in the operated state (NO contacts - closed and NC contacts - open), the mechanical indicator is visible in its window, the LED is not illuminated.

### **AUTO** position

The state of contacts, mechanical indicator and LED follow the coil supply voltage.

#### **OFF** position

Even if terminals A1 - A2 are supplied with rated voltage, the coil is not energized, and so the contacts remain in the non-operated state, the mechanical indicator is not visible and the LED is not illuminated.

B = LED

#### **C** = Mechanical indicator

## 4 ACCESSORIES

Auxiliary contact module available, "Quick assembly" with the main contactor 022.33/022.35.

#### OTHER DATA

It is suggested an air gap of 9 mm between adjacent relays for installations and working conditions close to the limit (that is, ambient temperature > 40 °C, coil operated for a prolonged period of time, all contacts loaded with current > 20 A).



