Features

- 2-channel isolated barrier
- 24 V DC supply (Power Rail)
- Input 2-wire and 3-wire SMART transmitters and 2-wire SMART current sources
- Output 0/4 mA ... 20 mA current sink/current source
- · Terminals with test points
- Up to SIL 2 acc. to IEC 61508

Function

This isolated barrier is used for intrinsic safety applications.

The device supplies 2-wire and 3-wire SMART transmitters, and can also be used with 2-wire SMART current sources.

It transfers the analog input signal to the safe area as an isolated current value.

Digital signals may be superimposed on the input signal in the hazardous or non-hazardous area and are transferred bidirectionally.

The device provides a sink mode or a source mode output on the safe area terminals.

The device has an internal resistor. Use this resistor if the HART communication resistance in the control circuit is too low

Test sockets for the connection of HART communicators are integrated into the terminals of the device.


Application

The device supports the following SMART protocols:

- HART
- BRAIN
- Foxboro

Assembly

Front view




 ϵ



SIL 2

Connection



JE.	
203645_eng.x	
Date of issue 2017-08-10	
Release date 2017-08-0914:39	

General specifications	
Signal type	Analog input
Functional safety related parameter	
Safety Integrity Level (SIL)	SIL 2
Supply	
Connection	Power Rail or terminals 14+, 15-
Rated voltage U _r	18 30 V DC
Ripple	within the supply tolerance
Power dissipation	≤ 1.4 W at maximium load
Power consumption	≤ 2.6 W at maximium load
Input	E 2.0 W dt maximum load
Connection side	field side
Connection	terminals 1+, 2-, 3; 4+, 5-, 6
	0/4 20 mA
Input signal	
Available voltage	≥ 16 V at 20 mA , terminals 1+, 3; 4+, 6
Output	control olds
Connection side	control side
Connection	terminals 7+, 8-, 9-; 10+, 11-, 12- (sink) terminals 7-, 8+, 9+; 10-, 11+, 12+ (source) see additional information
Load	$0 \dots 600 \Omega$
Output signal	0/4 20 mA (overload > 25 mA)
Ripple	≤ 50 μA _{rms}
Transfer characteristics	. 1110
Deviation	at 20 °C (68 °F), 0/4 20 mA ≤ 10 µA incl. calibration, linearity, hysteresis, loads and fluctuations of supply voltage
Influence of ambient temperature	≤ 0.25 µA/K
Frequency range	field side into the control side: band width with 1 V _{pp} signal 0 7.5 kHz (-3 dB) safe area to hazardous area: band width with 1 V _{SS} signal 0.3 7.5 kHz (-3 dB)
Settling time	200 μs
Rise time/fall time	100 μs
Galvanic isolation	
Output/power supply	functional insulation, rated insulation voltage 50 V AC
Output/Output	functional insulation, rated insulation voltage 50 V AC
Indicators/settings	Turiotional modulation, rated modulation voltage 55 v 70
Display elements	LED
Labeling	space for labeling at the front
Directive conformity	Space for labeling at the north
Electromagnetic compatibility	
Directive 2014/30/EU	EN 61326-1:2013 (industrial locations)
Conformity	LIV 01320-1.2013 (illidustrial locations)
Electromagnetic compatibility	NE 21:2012 EN 61326-3-2:2008
Degree of protection	IEC 60529:2001
Protection against electrical shock	UL 61010-1:2012
Ambient conditions	CESTO NEOTE
Ambient temperature	-20 60 °C (-4 140 °F)
Mechanical specifications	2533 37.1110.17
Degree of protection	IP20
Connection	screw terminals
Mass	approx. 200 g
Dimensions	20 x 124 x 115 mm (0.8 x 4.9 x 4.5 inch) , housing type B2
Mounting Pote for application in connection	on 35 mm DIN mounting rail acc. to EN 60715:2001
Data for application in connection with hazardous areas	ON AT ATEV COOK V
EU-Type Examination Certificate	CML 17 ATEX 2031 X
Marking	 ⟨ၹ⟩ II (1)G [Ex ia Ga] IIC ⟨ၹ⟩ II (1)D [Ex ia Da] IIIC ⟨ၹ⟩ I (M1) [Ex ia Ma] I
Input	[Ex ia Ga] IIC, [Ex ia Da] IIIC, [Ex ia Ma] I
Supply	
Maximum safe voltage U _m	250 V (Attention! The rated voltage can be lower.)
Equipment Equipment	terminals 1+, 3-; 4+, 6-
Voltage U _o	26.2 V
. 5.1.295	
Voltage U _q	27.25 V




Pepperl+Fuchs Group www.pepperl-fuchs.com

203645 eng.xm
2017-08-10 2
Date of issue 2
14:39
date 2017-08-09
ease

Power	Po	634 mW
Equipment	J	terminals 2-, 3+; 5-, 6+
Voltage	U _i	30 V
Current	I _i	115 mA
Power	P _i	max 1 W
Voltage	U_o	2 V
Current	Io	8.5 mA
Power	Po	4.3 mW
Equipment		terminals 1+, 2/3-; 4+, 5/6-
Voltage	U_o	26.2 V
Voltage	U_q	27.25 V
Current	Io	115 mA
Power	Po	784 mW
Certificate		CML 17 ATEX 3030 X
Marking		⟨⟨x⟩ II 3G Ex ec IIC T4 Gc
Galvanic isolation		
Input/Output		safe electrical isolation acc. to IEC/EN 60079-11:2012, voltage peak value 375 V
Input/power supply		safe electrical isolation acc. to IEC/EN 60079-11:2012, voltage peak value 375 V
Directive conformity		
Directive 2014/34/EU		EN 60079-0:2012+A11:2013 , EN 60079-11:2012 , EN 60079-7:2015
International approvals		
UL approval		
Control drawing		pending
IECEx approval		IECEx CML 17.0016X
Approved for		[Ex ia Ga] IIC, [Ex ia Da] IIIC, [Ex ia Ma] I, Ex ec IIC T4 Gc
General information		
Supplementary information	on	Observe the certificates, declarations of conformity, instruction manuals, and manuals where applicable. For information see www.pepperl-fuchs.com.

The device provides 2 outputs on the control side terminals. These outputs can be operated in any combination of the current sink operating mode and current source operating mode. Please refer to the following diagram for connection.



Accessories

Power feed module KFD2-EB2

The power feed module is used to supply the devices with 24 V DC via the Power Rail. The fuse-protected power feed module can supply up to 150 individual devices depending on the power consumption of the devices. Collective error messages received from the Power Rail activate a galvanically-isolated mechanical contact.

Power Rail UPR-03

The Power Rail UPR-03 is a complete unit consisting of the electrical insert and an aluminium profile rail 35 mm x 15 mm. To make electrical contact, the devices are simply engaged.

Profile Rail K-DUCT with Power Rail

The profile rail K-DUCT is an aluminum profile rail with Power Rail insert and two integral cable ducts for system and field cables. Due to this assembly no additional cable guides are necessary.



Power Rail and Profile Rail must not be fed via the device terminals of the individual devices!