

35 0X X XXXX X XX X X 00 (XX) (XXX) ← STANDARD EXCEPT No.

CODE	VARIANTS TO STANDARD TYPES
00	PRESSURE OUTPUT
05	REVERSE OUTPUT
08	8-20mA OUTPUT

CODE	RESTRICTOR
OF	FM APPROVED
HD	HEAVY DUTY

CODE	OUTPUT
7	0.5-5V
*B	4-20mA
C	1-6V
D	1-11V
G	0.2-10V
*H	1-5V
J	0.5-5.5V
*N	0.5-4.5V NON RATIOMETRIC
P	1-10V
R	0-5V
S	0-10V
*T	0.5-4.5V RATIOMETRIC

*(SEE NOTE 2)

CODE	PRESSURE RANGE
350M	350mbar
500M	500mbar
700M	700mbar
0001	1 bar
01B6	1.6 bar
02B5	2.5 bar
0004	4 bar
0006	6 bar
0010	10 bar
0016	16 bar
0040	40 bar
05P0	5 psi
010P	10 psi
015P	15 psi
030P	30 psi
050P	50 psi
100P	100 psi
150P	150 psi
200P	200 psi
250P	250 psi
600P	600 psi

CARDINAL PRESSURE RANGES SHOWN
INTERMEDIATE PRESSURE RANGES AVAILABLE
CONTACT BASINGSTOKE

CODE	DATUM
G	GAUGE
A	ABSOLUTE
V	COMPOUND
S	SEALED GAUGE

(SEE NOTE 1)

NOTE 1:
FOR COMPOUND RANGES USE "V" IN PLACE OF "G"
i.e. 000PV = -15 to 0 psiG
015PV = -15 to 15 psiG
0001V = -1 to 1 barG
0009V = -1 to 9 barG

*NOTE 2:
ELECTRICAL CONNECTION 9 (PACKARD METRIPAK)
ONLY AVAILABLE WITH OUTPUT CODES B, H, N & T

CODE	INTEGRAL PRESSURE CONNECTION
01	G1/4 EXTERNAL
02	1/4-18NPT EXTERNAL
04	7/16-20UNF EXTERNAL
05	G1/4 EXTERNAL SOFT SEAL
08	1/8-27NPT EXTERNAL
0L	M12 x 1.5 EXTERNAL
0A	R1/4-19 EXTERNAL
0S	G1/8 EXTERNAL
18	G1/2 EXTERNAL
1J	7/16-20 UNF EXTERNAL
5S	G1/4 O-RING SEAL
0H	1/2-14 NPT EXTERNAL
4D	1/8-27 NPTF EXTERNAL

**NOTE 3:
ELECTRICAL CONNECTIONS F & G NOT
AVAILABLE WITH PRESSURE PORTS -18 & -0H

NOTE 4:
MINIMUM CABLE LENGTH 1M
SET CABLE LENGTHS ONLY AVAILABLE WITH
F ELECTRICAL CONNECTOR
FOR OTHER CABLE LENGTHS CONSULT BASINGSTOKE


CODE	RESTRICTOR
O	NOT FITTED
R	FITTED

CODE	ELECTRICAL CONNECTION
8	DEUTSCH SERIES DT-04
*9	PACKARD METRIPAK
B	INDUSTRIAL DIN
E	M12 x 1
**F	INTEGRAL CABLE IP67
**G	DIN 43650A
K	INDUSTRIAL DIN CVD

*(SEE NOTE 2)
**(SEE NOTE 3)

CODE	CABLE LENGTH
00	NO CABLE
01	1M
02	2M
03	3M
04	4M
05	5M
06	6M
10	10M

(SEE NOTE 4)

ISS	1	A	B	C	D	THIS DRAWING & ANY INFORMATION OR DESCRIPTIVE MATTER SET-OUT HEREON ARE THE CONFIDENTIAL & COPYRIGHT PROPERTY OF GEMS SENSORS & CONTROLS & MUST NOT BE DISCLOSED, LOANED, COPIED OR USED FOR ANY OTHER PURPOSE WITHOUT THEIR WRITTEN CONSENT	 COMPUTER GENERATED DRAWING DO NOT CHANGE MANUALLY Gems Sensors & Controls BASINGSTOKE ENGLAND	DRAWN CHECKED ENG. CHECK MAN. ENG. APPROVED	S.R.F. --- 28.09.19 MS 28.8.19	05-09-13 --- 28-8-19	DRAWING NUMBER 559399-3500	ISSUE D
CHKD APP		TB										
ECN No.	EB-043/5	EB-045	E14-007	E16-016	E19-009							