SIEMENS

Product data sheet

3RT1065-6AF36



CONTACTOR,

132KW/400V/AC-3 AC(40...60HZ)/DC OPERATION UC 110-127V AUXILIARY CONTACTS 2NO+2NC 3-POLE, SIZE S10 BAR CONNECTIONS CONVENT. OPERATING MECHANISM SCREW TERMINAL

General details:		
product brand name		SIRIUS
product designation		power contactor
Size of the contactor		S10
Protection class IP / on the front		IP00
Degree of pollution		3
Installation altitude / at a height over sea level / maximum	m	2,000
Ambient temperature / during operating phase	°C	-25 60
Active power loss / per conductor / typical	W	18
Item designation		
according to DIN EN 61346-2		Q
 according to DIN 40719 extendable after IEC 204-2 / according to IEC 750 		К
Mechanical operating cycles as operating time	-	
of the contactor / typical		10,000,000
of the contactor with added auxiliary switch block / typical		10,000,000
 of the contactor with added electronics-compatible auxiliary switch block / typical 		5,000,000
Main circuit:		
Number of poles / for main current circuit		3

Number of NC contacts / for main contacts		0
Number of NO contacts / for main contacts		3
Operating current / at AC-1 / at 400 V / at 40 °C ambient temperature / rated value	A	330
Operating current / at AC-1 / at 400 V / at 60 °C ambient temperature / rated value	A	300
Operating current	-	
• at AC-3 / at 400 V / rated value	А	265
with 1 current path		
• at DC-1		
• at 24 V / rated value	А	300
• at 110 V / rated value	А	33
• at DC-3 / at DC-5		
• at 24 V / rated value	А	300
• at 110 V / rated value	А	3
with 2 current paths in series		
• at DC-1		
• at 24 V / rated value	А	300
• at 110 V / rated value	А	300
• at DC-3 / at DC-5		
• at 24 V / rated value	А	300
• at 110 V / rated value	А	300
• with 3 current paths in series		
• at DC-1		
• at 24 V / rated value	А	300
• at 110 V / rated value	А	300
• at DC-3 / at DC-5		
• at 24 V / rated value	А	300
• at 110 V / rated value	А	300
Service power		
• at AC-1 / at 400 V / rated value	kW	197
• at AC-2 / at 400 V / rated value	kW	151
• at AC-3		
• at 400 V / rated value	kW	132
• at 500 V / rated value	kW	189
• at 690 V / rated value	kW	265
Control circuit:		

Control circuit:	
Design of activation	conventional
Design of the surge suppressor	with varistor
Type of voltage / of the controlled supply voltage	AC/DC

Control supply voltage frequency		
• 1 / rated value	Hz	40
• 2 / rated value	Hz	60
Control supply voltage / 1	-	
• for DC		
initial rated value	V	110
final rated value	V	127
• at 50 Hz / for AC		
initial rated value	V	110
final rated value	V	127
• at 60 Hz / for AC		
• initial rated value	V	110
final rated value	V	127


Auxiliary	circuit:
Auxilialy	Gircuit.


Contact reliability / of the auxiliary contacts		1 faulty switching per 100 million (17 V, 1 mA)
Number of NC contacts / for auxiliary contacts		
 instantaneous switching 		2
lagging switching		0
Number of NO contacts / for auxiliary contacts		
 instantaneous switching 		2
leading switching		0
Operating current / of the auxiliary contacts		
• at AC-12 / maximum	А	10
• at AC-15		
• at 230 V	А	6
• at 400 V	А	3
• at DC-12		
• at 60 V	А	6
• at 110 V	А	3
• at 220 V	А	1
• at DC-13		
• at 24 V	А	10
• at 60 V	А	2
• at 110 V	А	1
• at 220 V	А	0.3

Short-circuit:

	_		
Design of the fuse link			
 for short-circuit protection of the auxiliary switch / required 		fuse gL/gG: 10 A	
 for short-circuit protection of the main circuit 			

 with type of as 	ssignment 1 / requ	ired		fuse gL/gG: 500 A	
 at type of coor 	rdination 2 / requir	ed		fuse gL/gG: 400 A	
nstallation/moun	ting/dimension	s:			
ype of mounting				screw fixing	
eries installation			_	Yes	
Vidth			mm	145	
leight			mm	210	
Depth			mm	202	
Distance, to be main	ntained, to earthe	ed part / sidewards	mm	10	
Connection type:					
Design of the electr	ical connection				
• for main current	circuit			screw-type terminals	
• for auxiliary and	control current circ	cuit		screw-type terminals	
dentification numb	er and letter for s	witching elements		22 E	
Certificates/appro	ovals:				
General Product A	pproval				Functional Safety / Safety of Machinery
CQC	SP	<u>KETI</u>	<u>ROSTEST</u>	(ŲL)	SUVA
Test Certificates		Shipping Approv	/al		
Manufacturer	other	ABS	ĴÅ Dinv	GLE OPERATING 2417	
other					
Manufacturer	other				
Further information	on:				
nformation- and Do		atalogs, Brochures,) rols/catalogs			
ndustry Mall (Onlin http://www.siemens.c					
CAx-Online-Genera					
http://www.siemens.c					
	lanuals, Certifica	tes, Characteristics, FAQ /WW/view/en/3RT1065-6AF			





last change:

Jul 18, 2011