



### Main

Device short name	MN
Product or component type	Voltage release
Device application	Control
Range compatibility	Masterpact NW Compact NS1600b...3200 Compact NS630b...1600 Masterpact NT
Offer type	C5 C4
Voltage release type	Undervoltage release
[Uc] control circuit voltage	48 V AC 48...60 V DC

### Complementary

Threshold tripping voltage	0.35...0.7 Un - during opening time 0.85 Un - during closing time
Supply holding power	4.5 W
Mounting mode	Fixed
Response time	40 ms Masterpact NT 90 ms Masterpact NW
Accessory / separate part category	Spare parts Masterpact NT Spare parts Masterpact NW Spare parts Compact NS1600b...3200 Spare parts Compact NS630b...1600

### Contractual warranty

Warranty period	18 months
-----------------	-----------