

# E4V4000PR121/P-LI In=4000A4pFHR



E4V 4000 PR121/P-LI In=4000A 4p F HR

## General Information

|                       |  |
|-----------------------|--|
| Extended Product Type | E4V4000PR121/P-LI In=4000A4pFHR  |
| Product ID            | 1SDA056920R1   |
| EAN                   | 8015644582609  |
| Catalog Description   | E4V 4000 PR121/P-LI In=4000A 4p F HR   |
| Long Description      | SACE EMAX CIRCUIT-BREAKER E4V 4000A FOUR-POLE FIXED WITH TERMINALS REAR HORIZONTAL OVERCURRENT RELEASE PR121/P-LI R4000 FITTED WITH: 4 AUXILIARY CONTACT AND C.BREAKER IN POSITION OPEN-CLOSED |

## Ordering

|                        |               |
|------------------------|---------------|
| EAN                    | 8015644582609 |
| Minimum Order Quantity | 1 piece       |
| Customs Tariff Number  | 85362090      |

## Dimensions

|                            |        |
|----------------------------|--------|
| Product Net Width          | 656 mm |
| Product Net Height         | 418 mm |
| Product Net Depth / Length | 302 mm |
| Product Net Weight         | 92 kg  |

## Container Information

|                                |               |
|--------------------------------|---------------|
| Package Level 1 Units          | 1 piece       |
| Package Level 1 Width          | 515 mm        |
| Package Level 1 Height         | 600 mm        |
| Package Level 1 Depth / Length | 920 mm        |
| Package Level 1 Gross Weight   | 111 kg        |
| Package Level 1 EAN            | 8015644582609 |

## Additional Information

|                       |   |
|-----------------------|---|
| Current Type          | AC  |
| Electrical Durability | Ue =< 440 V 5000 cycle<br>Ue = 500 ... 690 V 4000 cycle<br>10 cycles per hour |
| Mechanical Durability | 15000 cycle   |

|   |   |
|---|---|
|   | 60 cycles per hour  |
| Number of Poles   | 4   |
| Power Loss  | 360 W   |
| Product Main Type   | SACE Emax   |
| Product Name  | Air Circuit Breaker   |
| Product Type  | Air Circuit Breaker   |
| Rated Current ( $I_n$ )                                     | 4000 A  |
| Rated Voltage ( $U_r$ )                                     | 690 V   |
| Rated Impulse Withstand Voltage ( $U_{imp}$ )               | 12 kV   |
| Rated Insulation Voltage ( $U_i$ )                          | 1000 V  |
| Rated Operational Current ( $I_g$ )                         | 4000 A  |
| Rated Operational Voltage                                   | 690 V AC  |
| Rated Service Short-Circuit Breaking Capacity ( $I_{cs}$ )  | (220 V AC) 150 kA<br>(230 V AC) 150 kA<br>(380 V AC) 150 kA<br>(400 V AC) 150 kA<br>(415 V AC) 150 kA<br>(440 V AC) 150 kA<br>(500 V AC) 130 kA<br>(660 V AC) 100 kA<br>(690 V AC) 100 kA |
| Rated Short-time Withstand Current ( $I_{cw}$ )             | for 1 s 100 kA<br>for 3 s 75 kA   |
| Rated Ultimate Short-Circuit Breaking Capacity ( $I_{cu}$ ) | (220 V AC) 150 kA<br>(230 V AC) 150 kA<br>(380 V AC) 150 kA<br>(400 V AC) 150 kA<br>(415 V AC) 150 kA<br>(440 V AC) 150 kA<br>(500 V AC) 130 kA<br>(660 V AC) 100 kA<br>(690 V AC) 100 kA |
| Rated Uninterrupted Current ( $I_u$ )                       | 4000 A  |
| Release Type  | EL  |
| Standards   | IEC   |
| Sub-type  | E4  |
| Terminal Connection Type                                    | Fixed Circuit-Breakers<br>Rear flat Horizontal  |
| Version   | F   |

## Certificates and Declarations (Document Number)

|                                   |                 |
|-----------------------------------|-----------------|
| Data Sheet, Technical Information | 1SDC200006D0209 |
| Declaration of Conformity - CE    | 1SDL000165R0016 |
| Environmental Information         | 1SDL000145R0    |
| Instructions and Manuals          | 1SDH000460R0002 |

## Classifications

|                            |   |
|----------------------------|---|
| ETIM 4                     | EC000228 - Power circuit-breaker for trafo/generator/installation prot. |
| ETIM 5                     | EC000228 - Power circuit-breaker for trafo/generator/installation prot. |
| ETIM 6                     | EC000228 - Power circuit-breaker for trafo/generator/installation prot. |
| Object Classification Code | Q   |
| WEEE Category              | 4. Large Equipment (Any External Dimension More Than 50 cm)             |

—

### Categories

Low Voltage Products and Systems → Circuit Breakers → Air Circuit Breakers → Emax

