

# Vibration Limit Switch

# LVL-A7

- Limit switch for liquids
- Onsite function check possible thanks to LED indication
- Large selection of process connections for hassle-free installation in existing systems
- Easy to install even at points difficult to access due to compact design
- Rugged stainless steel housing
- Cost-saving plug connections
- Approval as overfill protection and leak detection system acc. to WHG

# **(** ii

#### Function

The Vibracon LVL-A7 is a limit switch for liquids and is used in tanks, vessels and pipes. The device is used for overfill prevention or pump protection in cleaning and filter systems as well as in cooling and lubrication vessels, for instance. The device is suitable for applications in which float switches or conductive, capacitance and optical sensors have been used up to now. The device also works in areas where these measuring principles are not suitable due to conductivity, buildup, turbulence, flow conditions or air bubbles.

The device can be used for process temperatures up to:


- 100 °C (212 °F) - 150 °C (302 °F)

The device is not suitable for use in hazardous areas.

For hygienic areas we recommend the use of Vibracon LVL A7H.

#### Connection

Example: electrical connection with M12 plug Further electrical connections see technical information (TI).





#### General specifications

Refer to "General Notes Relating to Pepperl+Fuchs Product Information"

Pepperl+Fuchs Group www.pepperl-fuchs.com USA: +1 330 486 0002 pa-info@us.pepperl-fuchs.com

Germany: +49 621 776 2222 pa-info@de.pepperl-fuchs.com Singapore: +65 6779 9091 pa-info@sg.pepperl-fuchs.com

1: BN

3: BU

4: BK





| Technical Data                   |    |   |
|----------------------------------|----|---|
|                                  |    |   |
| Measuring method                 |    | The tuning fork is brought to its resonance frequency by means of a piezoelectric drive<br>If the tuning fork is covered by liquid, this frequency changes. The electronics monitor<br>the resonance frequency and indicate whether the tuning fork is freely vibrating or is<br>covered by liquid.   |
| Construction type                |    | compact device<br>device with short tube  |
| Operating mode                   |    | MAX = maximum safety:<br>The device keeps the electronic switch closed as long as the liquid level is below the<br>fork.<br>example application: overspill protection<br>MIN = minimum safety:<br>The device keeps the electronic switch closed as long as the fork is immersed in liquid<br>example application: dry running protection of pumps<br>The electronic switch opens if the limit is reached, if a fault occurs or in the event of a<br>power fails (quiescent current principle) |
| Series                           |    | Vibracon LVL-A7   |
| Supply                           |    |   |
| Rated voltage                    | Ur | - DC-PNP: 10 35 V DC, 3-wire<br>- AC/DC: 20 253 V AC/DC, 2-wire   |
| Current consumption              |    | - DC-PNP: < 15 mA<br>- AC/DC: < 3.8 mA  |
| Power consumption                |    | - DC-PNP: < 975 mW<br>- AC/DC: < 850 mW   |
| Input                            |    |   |
| Measured variable                |    | density   |
| Measurement range                |    | min. 0.7 g/cm <sup>3</sup> , optional> 0.5 g/cm <sup>3</sup>  |
| Output                           |    |   |
| Output type                      |    | switch output   |
| Switching current                |    | max. 250 mA   |
| Directive conformity             |    |   |
| Electromagnetic compatibility    |    |   |
| Directive 2014/30/EU             |    | EN 61326-1:2006, EN 61326-2-3:2006  |
| Low voltage                      |    |   |
| Directive 2014/35/EU             |    | EN 61010-1:2010   |
| Conformity                       |    |   |
| Electromagnetic compatibility    |    | NE 21   |
| Degree of protection             |    | IEC 60529   |
| Shock resistance                 |    | EN 60068-2-27   |
| Vibration resistance             |    | EN 60068-2-64   |
| Climate class                    |    | DIN EN 60068-2-38/IEC 68-2-38   |
| Measurement accuracy             |    |   |
| Reference operating conditions   |    | <ul> <li>ambient temperature: 25 °C (+77 °F)</li> <li>process pressure: 1 bar (14.5 psi)</li> <li>fluid: water (density: approx. 1 g/cm<sup>3</sup>, viscosity: 1 mm<sup>2</sup>/s)</li> <li>medium temperature: 25 °C (+77 °F)</li> <li>density setting: &gt; 0.7 g/cm<sup>3</sup></li> <li>switching time delay: standard (0,5 s, 1 s)</li> </ul>   |
| Measured value resolution        |    | < 0.5 mm  |
| Measuring frequency              |    | approx. 1100 Hz in air  |
| Switching point                  |    | 13 mm ± 1 mm  |
| Non-repeatability                |    | ± 1 mm acc. to DIN 61298-2  |
| Hysteresis                       |    | max. 3 mm   |
| Influence of ambient temperature |    | negligible  |
| Influence of medium temperature  |    | -25 μm/°C   |
| Influence of medium pressure     |    | -20 μm/bar  |
| Switching time                   |    | <ul> <li>0.5 s when tuning fork is covered</li> <li>1.0 s when tuning fork is uncovered</li> <li>other switching times on request</li> </ul>  |
| Operating conditions             |    |   |
| Installation conditions          |    |   |
| Installation position            |    | see section mounting position   |
| installation position            |    |   |

 Refer to "General Notes Relating to Pepperl+Fuchs Product Information".

 Pepperl+Fuchs Group
 USA: +1 330 486 0002
 Gr

 www.pepperl-fuchs.com
 pa-info@us.pepperl-fuchs.com
 pa-info@us.pepperl-fuchs.com

Germany: +49 621 776 2222 pa-info@de.pepperl-fuchs.com

Singapore: +65 6779 9091 pa-info@sg.pepperl-fuchs.com

| Technical Data                     |   |
|------------------------------------|---|
| Ambient conditions                 |   |
|                                    |   |
| Ambient temperature                | -40 70 °C (-40 158 °F)  |
| Storage temperature                | -40 85 °C (-40 185 °F)  |
| Shock resistance                   | a = $300 \text{ m/s}^2$ = $30 \text{ g}$ , 3 planes x 2 directions x 3 shocks x 18 ms, as per test Ea   |
| Vibration resistance               | a(RMS) = 50 m/s <sup>2</sup> , ASD = 1.25 (m/s <sup>2</sup> ) <sup>2</sup> /Hz, f = 5 to 2000 Hz, t = 3 x 2 h   |
| Process conditions                 |   |
| Process temperature                | -40 +100 °C (-40 +212 °F)<br>-40 +150 °C (-40 +302 °F)  |
| Process pressure (static pressure) | -1 +40 bar (-14.5 +580 psi)   |
| State of aggregation               | liquid  |
| Density                            | min. 0.7 g/cm <sup>3</sup> , optional> 0.5 g/cm <sup>3</sup>  |
| Viscosity                          | 1 10000 mPa/s, dynamic viscosity  |
| Solid contents                     | < Ø5 mm   |
| Mechanical specifications          |   |
| Degree of protection               | - IP65/67, NEMA 4X enclosure (plug M12)<br>- IP65, NEMA 4X enclosure (valve plug)<br>- IP65/68, NEMA 4X/6P enclosure (cable)  |
| Connection                         | - cable 5 m<br>- valve plug NPT1/2<br>- valve plug QUICKON<br>- valve plug M16<br>- plug M12  |
| Material                           | see technical information (TI)  |
| Surface quality                    | $R_a < 3.2 \ \mu m$   |
| Mass                               | see technical information (TI)  |
| Dimensions                         | see technical information (TI)  |
| Process connection                 | - thread ISO 228 G1/2, G3/4, G1<br>- thread EN 10226 R1/2, R3/4, R1<br>- thread ASME MNPT1/2, MNPT3/4, MNPT1  |
| Indication and operation           |   |
| Display elements                   | The LED display is on the connection side.<br>- green LED: indication of ready to operate<br>- red LED: fault indication<br>- yellow LED: operating mode indication                       |
| Function test                      | function test with test magnet (optional accessory)   |
| Certificates and approvals         |   |
| Overspill protection               | Z-65.11-554 (overspill protection acc. to WHG)<br>Z-65.40-555 (leak detection system acc. to WHG)<br>If you need the approvals also in paper form, select the option WH in the type code. |
| General information                |   |
| Supplementary documentation        | technical information (TI)<br>manual (BA)<br>approval (ZE)  |
| Supplementary information          | Statement of Conformity, Declaration of Conformity, Attestation of Conformity and<br>instructions have to be observed where applicable. For information see www.pepper<br>fuchs.com.      |
| Accessories                        |   |
| Designation                        | see technical information (TI)  |
|                                    |   |

Refer to "General Notes Relating to Pepperl+Fuchs Product Information"


Pepperl+Fuchs Group www.pepperl-fuchs.com

3

#### Assembly

1

6



- 1 Compact version with valve plug
- 2 Short tube version with cable
- 3 Compact version with M12 plug
- 4 Short tube version with M12 plug
- Further device versions see technical information (TI).




4

#### Mounting

#### Mounting position

The device can be installed in any position in a vessel, pipe or tank. Foam formation does not affect the function.




1 Overfill prevention or upper level detection

2 Lower level detection

3 Dry running protection for pump

### **Installation Conditions**

The switch point (A) on the sensor depends on the orientation of the limit switch (water +25 °C (+77 °F), 1 bar (14.5 psi).



Vertical and horizontal orientation, dimensions in mm (inch)

## Type Code

о П

Release date: 2021-04-13 Date of issue: 2021-04-13 Filename: 275573\_eng.pdf

This overview does not mark options which are mutually exclusive. Option with \* = on request/in preparation. Option with \*\* = multiple options can be selected

| Device              |                          |  |  |  |
|---------------------|--------------------------|--|--|--|
| LVL-A7              | Limit switch for liquids |  |  |  |
| Process temperature |                          |  |  |  |
| Α                   | max. 100 °C (212 °F)     |  |  |  |
| В                   | max. 150 °C (302 °F)     |  |  |  |

USA: +1 330 486 0002 pa-info@us.pepperl-fuchs.com

Germany: +49 621 776 2222 pa-info@de.pepperl-fuchs.com Singapore: +65 6779 9091 pa-info@sg.pepperl-fuchs.com



| Process  | connection  |
|----------|---|
| G1       | Thread ISO 228 G1/2, 316L   |
| G2       | Thread ISO 228 G3/4, 316L, for installlation in weld-in adapter (accessory)   |
| G3       | Thread ISO 228 G1, 316L, fork length 66.4 mm (compact version) or 103.3 mm (short tube version)   |
| G4       | Thread ISO 228 G1, 316L, fork length 77.4 mm (compact version) or 116.8 mm (short tube version), for installlation in weld-in adapter (accessory) |
| G5       | Thread ISO 228 G3/4, 316L   |
| N1       | Thread ASME MNPT1/2, 316L   |
| N2       | Thread ASME MNPT3/4, 316L   |
| N3       | Thread ASME MNPT1, 316L   |
| R1       | Thread EN 10226 R1/2, 316L  |
| R2       | Thread EN 10226 R3/4, 316L  |
| R3       | Thread EN 10226 R1, 316L  |
| XX       | Special version   |
| Sensor   | type  |
| А        | Compact version 316L, Ra < 3.2 μm   |
| В        | Short tube version 316L, Ra < 3.2 $\mu$ m   |
| Х        | Special version   |
| Electric | al output   |
| E5       | 3-wire, 10 to 35 V DC, PNP  |
| WA       | 2-wire, 19 to 253 V AC/DC   |
| Electric | al connection   |
| PC       | Cable 5 m, IP65/68, NEMA 4X/6P  |
| PN       | Valve plug NPT1/2, ISO 4400, IP65, NEMA 4X  |
| PS       | Valve plug QUICKON, IP65, NEMA 4X   |
| PU       | Valve plug M16, ISO 4400, IP65, NEMA 4X   |
| V1       | Plug M12, IP65/67, NEMA 4X  |
| XX       | Special version   |
| Approv   | al  |
| NA       | Version for non-hazardous area inclusive approvals as overfill protection and leakage detection system acc. to WHG                                |
| CG       | CSA General Purpose inclusive approvals as overfill protection and leakage detection system acc. to WHG   |

Refer to "General Notes Relating to Pepperl+Fuchs Product Information".

#### **Additional Options**

| Service **         |  |  |  |  |  |
|--------------------|--|--|--|--|--|
| S1                 | Cleaned from oil and grease  |  |  |  |  |
| S2                 | Density setting > 0.5 g/cm <sup>2</sup>  |  |  |  |  |
| S3                 | Switching delay setting  |  |  |  |  |
| S4                 | Special service  |  |  |  |  |
| Test, cer          | Test, certificate ***  |  |  |  |  |
| S5                 | Material certificate, wetted metallic parts, EN 10204-3.1 inspection certificate             |  |  |  |  |
| S6                 | Final inspection report  |  |  |  |  |
| XX                 | Special version  |  |  |  |  |
| Addition           | Additional documents   |  |  |  |  |
| WH                 | Enclosed copies of approvals as overfill protection and leakage detection system acc. to WHG |  |  |  |  |
| Accessory optional |  |  |  |  |  |
| PA                 | Weld-in adapter G3/4, d = 50, 316L, vessel installation                                      |  |  |  |  |
| PB                 | Weld-in adapter G3/4, d = 50, 316L, vessel installation, EN 10204-3.1 inspection certificate |  |  |  |  |
| PC                 | Weld-in adapter G3/4, d = 29, 316L, pipe installation  |  |  |  |  |
| PD                 | Weld-in adapter G3/4, d = 29, 316L, pipe installation, EN 10204-3.1 inspection certificate   |  |  |  |  |
| PE                 | Weld-in adapter G1, d = 60, 316L, vessel installation  |  |  |  |  |
| PF                 | Weld-in adapter G1, d = 60, 316L, vessel installation, EN 10204-3.1 inspection certificate   |  |  |  |  |
| PG                 | Weld-in adapter G1, d = 53, 316L, pipe installation  |  |  |  |  |
| PH                 | Weld-in adapter G1, d = 53, 316L, pipe installation, EN 10204-3.1 inspection certificate     |  |  |  |  |
| RZ                 | Socket plug M12, elbowed 90 °, IP67, 5 m cable, slotted-nut Cu Sn/Ni                         |  |  |  |  |
| R1                 | Socket plug M12, IP67, slotted-nut Cu Sn/Ni  |  |  |  |  |
| R5                 | Assembly socket wrench   |  |  |  |  |
| ST                 | Test magnet  |  |  |  |  |
| SZ                 | Special version  |  |  |  |  |
| Marking            |  |  |  |  |  |
| S9                 | Tagging (TAG), see additional specifications   |  |  |  |  |
|                    |  |  |  |  |  |

Refer to "General Notes Relating to Pepperl+Fuchs Product Information"

Pepperl+Fuchs Group www.pepperl-fuchs.com