




PS 1/60/6-KNX, Busbar, 1phase, 60cont.



_

General Information

| Extended Product Type | PS1/60/6-KNX |
|-----------------------|--|
| Product ID | 2CDG924004R0011 |
| EAN | 4016779667593 |
| Catalog Description | PS 1/60/6-KNX, Busbar, 1phase, 60cont. |
| Long Description | The busbars reduce the wiring effort for ABB i-bus® modular installation devices. Different load circuits can be supplied from a common source using the busbar. The busbars are suitable for 6 sqmm terminals in the ABB i-bus® range, such as those installed in the 10 A and 16 A SA/S ABB i-bus® Switch Actuators, Switch/Dim Actuators SD/S x.16.1 or Light Controller LR/S 4.16.1. |
| Number of Batteries | 0 |

__

Ordering

| EAN | 4016779667593 |
|------------------------|---------------|
| Minimum Order Quantity | 1 piece |
| Customs Tariff Number | 85444995 |

__

Dimensions

| Product Net Width | 10.5 mm |
|----------------------------|---------|
| Product Net Height | 16 mm |
| Product Net Depth / Length | 1037 mm |
| Product Net Weight | 0.1 kg |

Container Information

| Package Level 1 Units | 1 piece |
|--------------------------------|---------------|
| Package Level 1 Width | 55 mm |
| Package Level 1 Height | 55 mm |
| Package Level 1 Depth / Length | 1250 mm |
| Package Level 1 Gross Weight | 0.11 kg |
| Package Level 1 EAN | 4016779667593 |

__

Additional Information

| Brand / Label | ABB |
|-----------------|-----|
| Connection Type | Pin |

PS1/60/6-KNX 2

| Number of Phases | 1 |
|---|------------------------------------|
| Number of Poles | 60 |
| Operational Voltage | Maximum (Incl. Tolerance) 400 V AC |
| Power Loss | 0 W |
| Product Main Type | Bus Bars and Wiring Jumpers |
| Product Name | Connection and Wiring |
| Rated Cross-Section | 6 mm² |
| Rated Impulse Withstand Voltage (U_{imp}) | 4 kV |
| Rated Short-time Withstand Current (I _{cw}) | 25 kA |
| Rated Uninterrupted Current (I_u) | 40 A |

__

Certificates and Declarations (Document Number)

| Data Sheet, Technical Information | 2CDC503030D0201 |
|-----------------------------------|-----------------|
| Declaration of Conformity - CE | 2CDK503006D2702 |
| Instructions and Manuals | 2CDC503030D0201 |

_

Classifications

| ETIM 4 | EC000699 - Central device for bus system |
|----------------------------|---|
| ETIM 5 | EC000215 - Phase busbar |
| ETIM 6 | EC000215 - Phase busbar |
| ETIM 7 | EC000215 - Phase busbar |
| Object Classification Code | A |
| WEEE Category | 4. Large Equipment (Any External Dimension More Than 50 cm) |
| eClass | 7.0 27371306 |

_

Categories

 $Low\ Voltage\ Products\ and\ Systems\ \rightarrow\ Home\ and\ Building\ Automation\ \rightarrow\ KNX\ \rightarrow\ Connection\ and\ Wiring\ \rightarrow\ Bus\ Bars\ and\ Wiring\ Jumpers$

