
## TURCK

# Inductive sensor With extended temperature range NI10-P18-Y1X/S97





Type designation	NI10-P18-Y1X/S97
Ident no.	4035121

Rated switching distance Sn	10 mm
Mounting conditions	Non-flush
Secured operating distance	≤ (0,81 x Sn) mm
Correction factors	St37 = 1; Al = 0.3; stainless steel = 0.7; Ms = 0.4
Repeat accuracy	≤ 2 % of full scale
Temperature drift	≤ <b>±</b> 10 %
	≤ ± 20 %, ≤ -25 °C
Hysteresis	110 %
Ambient temperature	-40+70 °C
	For explosion hazardous areas see instruction
	leaflet


Output function	2-wire, NAMUR	
Switching frequency	0.5 kHz	
Voltage	Nom. 8.2 VDC	
Non-actuated current consumption	≥ 2.1 mA	
Actuated current consumption	≤ 1.2 mA	

Approval acc. to	KEMA 02 ATEX 1090X

Approval acc. to	KEMA 02 ATEX 1090X	
Design	Threaded barrel,M18 × 1	
Dimensions	34 mm	
Housing material	Plastic, PA12-GF30	
Active area material	,	
End cap	Plastic, EPTR	
Max. tightening torque housing nut	2 Nm	
Electrical connection	Cables	
Cable quality	5.2 mm, SiHSi, Silicone, 2m	
Cable cross section	2 x 0.5 mm <sup>2</sup>	
Vibration resistance	55 Hz (1 mm)	
Shock resistance	30 g (11 ms)	
Protection class	IP67	
MTTF	6198 years acc. to SN 29500 (Ed. 99) 40 °C	
Packaging unit	1	
Switching state	LED,Yellow	

- ATEX category II 2 G, Ex zone 1
- ATEX category II 1 D, Ex-zone 20 for temperatures up to -25 °C
- SIL2 (Low Demand Mode) acc. to IEC 61508, PL c acc. to ISO 13849-1 at HFT0
- SIL3 (All Demand Mode) acc. to IEC 61508, PL e acc. to ISO 13849-1 with redundant configuration HTF1
- Threaded barrel, M18 x 1
- Plastic, PA12-GF30-V0
- Temperatures up to -40 °C
- DC 2-wire, nom. 8.2 VDC
- Output acc. to DIN EN 60947-5-6 (NA-MUR)
- Cable connection

### Wiring Diagram



### **Functional principle**


Inductive sensors detect metal objects contactless and wear-free. For this purpose they use a high-frequency electromagnetic AC field that interacts with the target. The sensors hosting a ferrite core coil generate the AC field through an LC resonant circuit.

Special versions are available for ambient temperatures between -60°C and +250°C.



# Inductive sensor With extended temperature range NI10-P18-Y1X/S97

Distance D	3 x B
Distance W	3 x Sn
Distance T	3 x B
Distance S	1.5 x B
Distance G	6 x Sn
Distance N	2 x Sn
Diameter active area B	Ø 18 mm





# Industri<mark>al</mark> Au<mark>tomation</mark>

# Inductive sensor With extended temperature range NI10-P18-Y1X/S97

### Accessories

Type code	Ident no.	Description	
QM-18	6945102	Quick-mount bracket with dead-stop; material: Chrome-plated brass Male thread M24 x 1.5. Note: The switching distance of proximity switches can be reduced by the use of quick-mount brackets.	M24 x 1,5
BST-18B	6947214	Fixing clamp for threaded barrel devices, with dead-stop; material: PA6	M5 28 40 24 24 24
MW-18	6945004	Mounting bracket for threaded barrel devices; material: Stainless steel A2 1.4301 (AISI 304)	5.5 9.5 44,5 1,8 7,9 115,9 19,1 50,8 14,3 34,8
BSS-18	6901320	Mounting bracket for smooth and threaded barrel devices; material: Polypropylene	o 18 26 32 32 40.5 30
IMX12-DI01-2S-2T-0/ 24VDC	7580020	Isolating switching amplifier, 2-channel; SIL2 acc. to IEC 61508; Ex-proof version; 2 transistor outputs; input Namur signal; ON/OFF switchable monitoring of wire-break and short-circuit; toggle between NO/NC mode; signal doubling; removable screw terminals; 12.5 mm wide; 24 VDC power supply	117

# TURCK

**Automation** 

Industrial

# Inductive sensor With extended temperature range NI10-P18-Y1X/S97

### Operating manual

### Intended use

This device fulfills the directive 2014/34/EC and is suited for use in explosion hazardous areas according to EN 60079-0:2012 + A11 and EN 60079-11:2012.

Further it is suited for use in safety-related systems, including SIL2 as per IEC 61508.

In order to ensure correct operation to the intended purpose it is required to observe the national regulations and directives.

#### For use in explosion hazardous areas conform to classification

II 2 G and II 1 D (Group II, Category 2 G, electrical equipment for gaseous atmospheres and category 1 D, electrical equipment for dust atmospheres).

### Marking (see device or technical data sheet)

#### Local admissible ambient temperature

-40...+70 °C

#### Installation/Commissioning

These devices may only be installed, connected and operated by trained and qualified staff. Qualified staff must have knowledge of protection classes, directives and regulations concerning electrical equipment designed for use in explosion hazardous areas.

Please verify that the classification and the marking on the device comply with the actual application conditions.

This device is only suited for connection to approved Exi circuits according to EN 60079-0 and EN 60079-11. Please observe the maximum admissible electrical values.

After connection to other circuits the sensor may no longer be used in Exi installations. When interconnected to (associated) electrical equipment, it is required to perform the "Proof of intrinsic safety" (EN60079-14).

Attention! When used in safety systems, all content of the security manual must be observed.

### Installation and mounting instructions

Avoid static charging of cables and plastic devices. Please only clean the device with a damp cloth. Do not install the device in a dust flow and avoid build-up of dust deposits on the device.

If the devices and the cable could be subject to mechanical damage, they must be protected accordingly. They must also be shielded against strong electro-magnetic fields.

The pin configuration and the electrical specifications can be taken from the device marking or the technical data sheet.

### Service/Maintenance

Repairs are not possible. The approval expires if the device is repaired or modified by a person other than the manufacturer. The most important data from the approval are listed.