



### Main

Range of product	Acti 9
Range	Acti 9
Product name	Acti 9 IC
Product or component type	Twilight switch
Device short name	IC2000
Provided equipment	Switchboard cell
Function available	Cabling test function with a push-button on front face

### Complementary

Device application	Building
Number of channels	1
Load type	( 400 VA ) Balast : conventional, ( 1500 VA ) Balast : conventional, ( 2300 VA ) Balast : conventional, ( 2300 VA ) Balast : conventional, ( 2300 VA ) Balast : conventional, ( 400 VA ) ( 2300 W ) ( 2300 W ) Balast : electronic, ( 300 VA ) Balast : electronic, ( 7 x 15 W ) Balast : electronic, ( 7 x 20 W ) Balast : electronic, ( 7 x 23 W ) Balast : electronic, ( 9 x 7 W ) Balast : electronic, ( 7 x 11 W )
Power consumption in VA	6 VA
Maximum switching current	10 A - 250 V AC pf = 0.6 16 A - 250 V AC pf = 1
[Ue] rated operational voltage	230 V ( +10 % -15 % ) AC 50/60 Hz
Opening distance	< 3 mm
Status LED	Green LED : threshold reached Red LED : brightness less than the threshold
Time delay	>= 60 s ( on closing )


>= 60 s ( on breaking contact )

Mounting support	DIN rail
9 mm pitches	5
Light intensity adjustment	2...2000 lux
Connections - terminals	X 2 screwless terminals : <= 2.5 mm <sup>2</sup>
Electrical insulation class	Class II
Height	85 mm
Width	45 mm
Depth	65 mm
Product weight	280 g
Control type	By brightness detection
Market segment	Residential Small commercial
Compatibility code	IC2000

## Environment

Standards	EN 60669 EN 60529
Ambient air temperature for operation	-25...50 °C
IP degree of protection	IP20 B

## Offer Sustainability

Sustainable offer status	Green Premium product
RoHS (date code: YYWW)	Compliant - since 1426 - Schneider Electric declaration of conformity  <a href="#">Schneider Electric declaration of conformity</a>
REACH	Reference not containing SVHC above the threshold <a href="#">Reference not containing SVHC above the threshold</a>
Product environmental profile	Available
Product end of life instructions	Available

## Contractual warranty

Warranty period	18 months
-----------------	-----------