# **CompactLogix Power Supplies Specifications**

## 1768 CompactLogix Power Supplies Catalog **Numbers** 1768-PA3, 1768-PB3

# 1769 Compact I/O Power Supplies Catalog Numbers

1769-PA2, 1769-PB2, 1769-PA4, 1769-PB4

| Topic                            | Page |
|----------------------------------|------|
| 1768 CompactLogix Power Supplies | 3    |
| 1769 Compact I/O Power Supplies  | 7    |

#### **Environmental Specifications - 1768 and 1769 Power Supplies**

| Attribute  | 1768-PA3, 1769-PB3<br>1769-PA2, 1769-PB2, 1769-PA4, 1769-PB4 |
|--|--|
| Temperature, operating IEC 60068-2-1 (Test Ad, Operating Cold), IEC 60068-2-2 (Test Bd, Operating Dry Heat), IEC 60068-2-14 (Test Nb, Operating Thermal Shock)   | 060 °C (32140 °F)  |
| Temperature, storage IEC 60068-2-1 (Test Ab, Unpackaged Nonoperating Cold), IEC 60068-2-2 (Test Bb, Unpackaged Nonoperating Dry Heat), IEC 60068-2-14 (Test Na, Unpackaged Nonoperating Thermal Shock) | -4085 °C (-40185 °F)   |
| Relative humidity<br>IEC 60068-2-30 (Test Db, Unpackaged Nonoperating Damp Heat)   | 595% noncondensing   |
| Vibration<br>IEC 60068-2-6 (Test Fc, Operating)  | 5 g @ 10500 Hz   |
| Shock, operating<br>IEC 60068-2-27 (Test Ea, Unpackaged Shock)   | 30 g   |
| Shock, nonoperating<br>IEC 60068-2-27 (Test Ea, Unpackaged Shock)  | 50 g   |



#### Important User Information

Solid state equipment has operational characteristics differing from those of electromechanical equipment. Safety Guidelines for the Application, Installation and Maintenance of Solid State Controls (publication SGI-1.1 available from your local Rockwell Automation sales office or online at <a href="http://www.rockwellautomation.com/literature/">http://www.rockwellautomation.com/literature/</a>) describes some important differences between solid state equipment and hard-wired electromechanical devices. Because of this difference, and also because of the wide variety of uses for solid state equipment, all persons responsible for applying this equipment must satisfy themselves that each intended application of this equipment is acceptable.

In no event will Rockwell Automation, Inc. be responsible or liable for indirect or consequential damages resulting from the use or application of this equipment.

The examples and diagrams in this manual are included solely for illustrative purposes. Because of the many variables and requirements associated with any particular installation, Rockwell Automation, Inc. cannot assume responsibility or liability for actual use based on the examples and diagrams.

No patent liability is assumed by Rockwell Automation, Inc. with respect to use of information, circuits, equipment, or software described in this manual.

Reproduction of the contents of this manual, in whole or in part, without written permission of Rockwell Automation, Inc., is prohibited.

Throughout this manual, when necessary, we use notes to make you aware of safety considerations.

#### WARNING



Identifies information about practices or circumstances that can cause an explosion in a hazardous environment, which may lead to personal injury or death, property damage, or economic loss.

#### **IMPORTANT**

Identifies information that is critical for successful application and understanding of the product.

#### **ATTENTION**



Identifies information about practices or circumstances that can lead to personal injury or death, property damage, or economic loss. Attentions help you identify a hazard, avoid a hazard, and recognize the consequence

#### SHOCK HAZARD



Labels may be on or inside the equipment, for example, a drive or motor, to alert people that dangerous voltage may be present.

#### **BURN HAZARD**



Labels may be on or inside the equipment, for example, a drive or motor, to alert people that surfaces may reach dangerous temperatures.

Rockwell Automation, Rockwell Software, Allen-Bradley, TechConnect, Compact I/O, and CompactLogix are trademarks of Rockwell Automation, Inc.


Trademarks not belonging to Rockwell Automation are property of their respective companies

## 1768 CompactLogix Power **Supplies**

The 1768 backplane requires one 1768 power supply. The power supply is a dual input supply that operates in multiple ranges. The power supply also offers a 24V dc external power source. The power supply sends 24V dc to the controller in slot 0.

- The controller converts the 24V dc to 5V dc and 24V dc and distributes it as needed.
  - 5V and 24V power to 1769 I/O modules on the right side of the controller
  - 24V power to 1768 modules on the left side of the controller

Power supply sends 24V DC to the controller.



- 5V and 24V DC to 1769 I/O modules

The 1768 modules do not have a distance rating to the 1768 power supply. For the 1769 I/O modules in the 1768 system, the distance rating is from the controller and not the 1768 power supply.

#### Technical Specifications - 1768 CompactLogix Power Supplies

| Attribute             | 1768-PB3 1768-PB3   |                                    |  |
|-----------------------|---|------------------------------------|--|
| Input voltage range   | 85265V AC<br>108132V DC   | 16.831.2V DC                       |  |
| Input voltage, nom    | 120V/220V AC  | 24V DC                             |  |
| Input frequency range | 4763 Hz   | DC                                 |  |
| Input power, max      | 120VA/120 W   | 112 W                              |  |
| Output power, max     | 90 W<br>24V DC to backplane: 3.5<br>24V DC to user-accessible terminal block: 0.25 A  | 24V DC to backplane: 3.5           |  |
| Output power, min     | 6 W<br>24V DC to backplane: 0.25 A<br>24V DC to user-accessible terminal block: 0.0 A | 24V DC to backplane: 0.25 A        |  |
| Power dissipation     | 30 W  | 22 W                               |  |
| Inrush current, max   | 50 A @ 85132V AC<br>80 A @ 195265V AC   | 50 A @ 16.831.2V DC <sup>(1)</sup> |  |

#### **Technical Specifications - 1768 CompactLogix Power Supplies**

| Attribute                                       | 1768-PA3   | 1768-PB3   |  |
|---|--|--|--|
| Isolation voltage                               | 250V, reinforced insulation type, input to system and 24V DC AUX Tested at 4250V DC for 60 s 150V, basic insulation type, 24V DC AUX to system Tested at 2200V dc for 60 s |  |  |
| Internal overcurrent protection                 | Non-replaceable fuse is soldered in place  | Non-replaceable fuse is soldered in place            |  |
| Recommended external overcurrent protection     | 46 A @ 28.536.7 A <sup>2</sup> S 812 A @ 166250 A <sup>2</sup> S   |  |  |
| Overcurrent protection                          | 15 A, user supplied  |  |  |
| Weight, approx.                                 | 0.98 kg (2.15 lb)  | 1.01 kg (2.22 lb)                                    |  |
| Dimensions (HxWxD), approx.                     | 131.25 x 132.75 x 105.50 mm (5.17 x 5.23 x 4.15 in.)   | 131.25 x 132.75 x 105.50 mm (5.17 x 5.23 x 4.15 in.) |  |
| Module location                                 | DIN rail or panel mount  |  |  |
| Mounting screw torque                           | 1.16 N•m (10 lb•in) - use M4 or #8 screws  |  |  |
| Wire category                                   | 1 - on power ports <sup>(2)</sup>  |  |  |
| Wire size, input power terminal                 | 14 AWG (2.5 mm²) solid or stranded copper wire rated at 75 °C (167 °F) or greater, 1.2 mm (3/64 in.) insulation maximum  |  |  |
| Wire size, output power terminal                | 14 AWG (2.5 mm²)22 AWG (0.25 mm²) solid or stranded copper wire rated at 75 °C (167 °C) or greater, 1.2 mm (3/64 in.) insulation max                                       |  |  |
| Conductor screw torque                          | 0.6 N • m (5 lb • in)  |  |  |
| North American temperature code                 | T4   |  |  |
| Output #1: 24V DC to backplane                  | •  |  |  |
| Ride-through interval time, min                 | 25 ms @ 90 W   | 5 ms @ 90 W  |  |
| Full power hold-up interval                     | 5 ms @ 90 W  |  |  |
| Extended hold-up interval                       | 812 s @ 1.25 W   |  |  |
| Output #2: 24V DC to front panel terminal block | ·  |  |  |
| Voltage   | 1827.60V @ front panel   |  |  |
| Output disable                                  | Disable output during hold-up periods  |  |  |
| Enclosure type rating                           | None (open-style)  |  |  |

<sup>(1)</sup> Does not include X-capacitor charging current.

Use this conductor category information for planning conductor routing as described in the system level installation manual. See the Industrial Automation Wiring and Grounding Guidelines, publication 1770-4.1.


#### Certifications - 1768 CompactLogix Power Supplies

| Certification <sup>(1)</sup> | 1768-PA3, 1768-PB3   |
|------------------------------|--|
| c-UL-us                      | UL Listed Industrial Control Equipment, certified for US and Canada. See UL File E65584.                                 |
|                              | UL Listed for Class I, Division 2 Group A,B,C,D Hazardous Locations, certified for U.S. and Canada. See UL File E194810. |
| CE                           | European Union 89/336 EEC EMC Directive, compliant with:  • EN 50082-2: Industrial Immunity                              |
|                              | EN 61326-1; Meas./Control/Lab., Industrial Requirements  |
|                              | EN 61000-6-2; Industrial Immunity  |
|                              | EN 61000-6-4; Industrial Emissions   |
|                              | EN 61131-2; Programmable Controllers (Clause 8, Zone A & B)  |
|                              | European Union 73/23/EEC LVD Directive, compliant with:  |
|                              | EN 1010-1; Meas./Control/Lab   |
| C-Tick                       | Australian Radiocommunications Act, compliant with: AS/NZS CISPR 11; Industrial Emissions                                |


<sup>(1)</sup> When marked. See the Product Certification link at <a href="http://www.ab.com">http://www.ab.com</a> for Declarations of Conformity, Certificates, and other certification details.

# Power Requirements and Transformer Sizing - 1768 CompactLogix Power Supplies


#### 1768-PA3 Power Dissipation




#### 1768-PA3 Input Power Requirements




#### 1768-PB3 Power Dissipation




#### 1768-PB3 Input Power Requirements



# **Mounting Dimensions - 1768 CompactLogix Power Supplies**





# 1769 Compact I/O Power Supplies

Each 1769-L3x controller and additional bank of I/O modules requires a 1769 power supply. Place 1769 I/O modules to the left or right of the 1769 power supply. As many as eight I/O modules can be placed on each side of the power supply.

Each 1769 module also has a power supply distance rating (the number of modules from the power supply). Each module must be located within its distance rating. See the specifications for the module to determine its distance rating.

#### Technical Specifications - 1769 Compact I/O Power Supplies

| Attribute                       | 1769-PA2   | 1769-PB2   | 1769-PA4  | 1769-PB4   |  |
|---------------------------------|--|--|---|--|--|
| Input voltage range             | 85265V AC  | 19.231.2V DC   | 85265V AC or<br>170265V AC,<br>switch selectable  | 19.231.2V DC   |  |
| Input voltage, nom              | 120V/220V AC   | 24V DC   | 120V/220V AC  | 24V DC   |  |
| Power consumption               | 100 VA @ 120V AC   | 50 VA @ 24V DC   | 200 VA @ 120V AC  | 100 VA @ 24V DC  |  |
|                                 | 130 VA @ 240V AC   |  | 240 VA @ 240V AC  |  |  |
| Power dissipation               | 8 W @ 60° C (140° F)   | 7.5 W @ 60° C (140° F)   | 18 W @ 60° C (140° F)   | 14.5 W @ 60° C (140° F)  |  |
| Current capacity @ 5V           | 2.0 A  | 2.0 A  | 4.0 A   | 4.0 A  |  |
| Current capacity @ 24V          | 0.8 A  | 0.8 A  | 2.0 A   | 2.0 A  |  |
| Inrush current, max             | 25 A @ 132V AC   | 30 A @ 31.2V DC  | 25 A @ 132V AC  | 30 A @ 31.2V DC  |  |
| Isolation voltage               | 265V (continuous), reinforced insulation type (IEC Class 1 grounding required) Routine tested @ 2596V DC for 1 s, AC power input to system and AC power input to 24V DC user power | 75V (continuous),<br>reinforced insulation type<br>(IEC Class 1 grounding<br>required)<br>Routine tested at<br>1697V DC for 1 s, DC<br>power input to system | 265V (continuous),<br>reinforced insulation type<br>(IEC Class 1 grounding<br>required)<br>Routine tested at<br>2596V DC for 1 s, AC<br>power input to system | 75V (continuous),<br>reinforced insulation type<br>(IEC Class 1 grounding<br>required)<br>Routine tested at<br>1697V DC for 1 s, DC<br>power input to system |  |
| Fuse type                       | Wickmann 19195-3.15A   | Wickmann 19193-6.3A  | Wickmann 19195-3.15A  | Wickmann 19193-6.3A  |  |
|                                 | Littelfuse 02183.15MXP   | Littelfuse 021706.3MXP   | Littelfuse 02183.15MXP  | Littelfuse 021706.3MXP   |  |
| Weight, approx.                 | 525 g (1.16 lb)  |  | 630 g (1.39 lb)   | •  |  |
| Dimensions (HxWxD), approx.     | 118 x 70 x 87 mm (4.65 x 2.7   | '6 x 3.43 in.)   | •   |  |  |
| Module location                 | DIN rail or panel mount  |  |   |  |  |
| Mounting screw torque           | 1.16 N•m (10 lb•in) - use M  | 4 or #8 screws   |   |  |  |
| Power supply distance rating    | 8  | 8  |   |  |  |
|                                 | 8 I/O modules can be conne   | 8 I/O modules can be connected on either side of the power supply for a maximum of 16 modules  |   |  |  |
| Wire category <sup>(1)</sup>    | 1 - on power ports   | 2 - on power ports   | 1 - on power ports  | 2 - on power ports   |  |
| Wire size                       | 14 AWG (2.5 mm²) solid cop   | 14 AWG (2.5 mm²) solid copper wire rated at 90 °C (194 °F) or greater, 1.2 mm (3/64 in.) insulation max  |   |  |  |
| North American temperature code | T3C  |  |   |  |  |
| IEC temperature code            | _  | T4   | _   | T4   |  |
| Enclosure type rating           | None (open-style)  |  |   |  |  |

<sup>(1)</sup> Use this conductor category information for planning conductor routing as described in the system level installation manual. See the Industrial Automation Wiring and Grounding Guidelines, publication 1770-4.1.


#### **Certifications - 1769 Compact Power Supplies**


| Certification <sup>(1)</sup> | 1769-PA2, 1769-PA4   | 1769-PB2, 1769-PB4   |  |
|------------------------------|--|--|--|
| c-UL-us                      | UL Listed for Class 1, Division 2 Group A,B,C,D Hazardous Locations, certified for U.S. and Canada. See UL File E10314               |  |  |
| CE                           | European Union 2004/108/EC EMC Directive, compliant with:  • EN 61000-6-2; Industrial Immunity  • EN 61000-6-4; Industrial Emissions |  |  |
| C-Tick                       | Australian Radiocommunications Act, compliant with:<br>AS/NZS CISPR 11; Industrial Emissions   |  |  |
|                              |  | European Union 94/9/EC ATEX Directive, compliant with:  • EN 60079-15; Potentially Explosive Atmospheres, Protection "n" (Zone 2)  • EN 60079-0; General Requirements (Zone 2) |  |


<sup>(1)</sup> When marked. See the Product Certification link at <a href="http://www.ab.com">http://www.ab.com</a> for Declarations of Conformity, Certificates, and other certification details.

# Power Requirements and Transformer Sizing - 1769 CompactLogix Power Supplies


#### 1769-PA2 Output Derating








#### 1769-PA2 Power Disspation




Bus +5V, +24V, and User Load (Watts)

#### 1769-PB2 Output Derating




1769-PB2 Power Dissipation



Bus +5V, +24V, and User Load (Watts)


#### 1769-PA4 Output Derating

Total Output: 68 W @ 55 °C (131 °F) or below 61 W @ 60 °C (140 °F) or below




#### 1769-PB4 Output Derating

Total Output:  $68 \ W \ @ 55 \ ^\circ C \ (131 \ ^\circ F)$  or below  $61 \ W \ @ 60 \ ^\circ C \ (140 \ ^\circ F)$  or below




#### 1769-PA4 Power Disspation



Bus +5V, +24V, and User Load (Watts)

#### 1769-PB4 Power Disspation



Bus +5V, +24V, and User Load (Watts)

# 70 mm (2.76 in.) 87 mm (3.42 in.) 131.7 mm (5.18 in.)

# **Mounting Dimensions - 1769 CompactLogix Power Supplies**

Notes:

## **Rockwell Automation Support**

Rockwell Automation provides technical information on the Web to assist you in using its products. At <a href="http://www.rockwellautomation.com/support/">http://www.rockwellautomation.com/support/</a>, you can find technical manuals, a knowledge base of FAQs, technical and application notes, sample code and links to software service packs, and a MySupport feature that you can customize to make the best use of these tools.

For an additional level of technical phone support for installation, configuration, and troubleshooting, we offer TechConnect support programs. For more information, contact your local distributor or Rockwell Automation representative, or visit <a href="http://www.rockwellautomation.com/support/">http://www.rockwellautomation.com/support/</a>.

#### Installation Assistance

If you experience an anomoly within the first 24 hours of installation, review the information that is contained in this manual. You can contact Customer Support for initial help in getting your product up and running.

| United States or Canada | 1.440.646.3434  |
|-------------------------|---|
|                         | Use the <u>Worldwide Locator</u> at <a href="http://www.rockwellautomation.com/support/americas/phone_en.html">http://www.rockwellautomation.com/support/americas/phone_en.html</a> , or contact your local Rockwell Automation representative. |

#### New Product Satisfaction Return

Rockwell Automation tests all of its products to ensure that they are fully operational when shipped from the manufacturing facility. However, if your product is not functioning and needs to be returned, follow these procedures.

|                       | Contact your distributor. You must provide a Customer Support case number (call the phone number above to obtain one) to your distributor to complete the return process. |
|-----------------------|---|
| Outside United States | Please contact your local Rockwell Automation representative for the return procedure.  |

### **Documentation Feedback**

Your comments will help us serve your documentation needs better. If you have any suggestions on how to improve this document, complete this form, publication <u>RA-DU002</u>, available at <a href="http://www.rockwellautomation.com/literature/">http://www.rockwellautomation.com/literature/</a>.

#### www.rockwellautomation.com

#### Power, Control and Information Solutions Headquarters

Americas: Rockwell Automation, 1201 South Second Street, Milwaukee, WI 53204 USA, Tel: (1) 414.382.2000, Fax: (1) 414.382.4444

Europe/Middle East/Africa: Rockwell Automation, Vorstlaan/Boulevard du Souverain 36, 1170 Brussels, Belgium, Tel: (32) 2 663 0600, Fax: (32) 2 663 0640

Asia Pacific: Rockwell Automation, Level 14, Core F, Cyberport 3, 100 Cyberport Road, Hong Kong, Tel: (852) 2887 4788, Fax: (852) 2508 1846